



- A. 1-5 1/4" M.V.O. HYDRANT WITH 2-2 1/2" N.S.T. AND 1-4" PUMPER, SEATTLE STANDARD THREAD-M.J. INLET, WITH LUGS, BRASS TO BRASS SUB-SEAT.
- B. 1-AUXILIARY GATE VALVE: 6" AWWA C509 OR C515, RESILIENT SEAT, "O" RING STEM SEAL, M.J.xFL. WITH LUGS.
- C. 1-TWO-PIECE CAST IRON VALVE BOX EQUAL TO RICH SEATTLE TYPE #940.
- D. 1-6" DUCTILE IRON CLASS 52 CEMENT-LINED PIPE, LENGTH TO FIT.
- E. 2 - 3/4" GALVANIZED STEEL SHACKLE RODS, TAR SEALED AFTER ASSEMBLY.
- F. 1/4 CY - 1:3:6: CONCRETE MIX, POUR IN PLACE TO BLOCK. MAINTAIN CLEARANCE FOR BOLTS.
- G. 5" X 4" FEMALE SEATTLE STANDARD THREAD RIGID 5" STORZ ADAPTOR WITH ALL CAPS AND CHAINS OR CABLES. ADAPTOR MATERIAL TO BE ANODIZED ALUMINUM.

NOTES:

1. FIRE HYDRANT EXTENSION, IF REQUIRED.
2. FIRE HYDRANT TO BE PAINTED WITH TWO COATS OF HIGH GLOSS OSHA SAFETY YELLOW ENAMEL PAINT.
3. INSTALL BLUE - TYPE 2 R.P.M. ON STREET SURFACE ADJACENT TO MAIN PORT.

CITY OF KIRKLAND

PLAN NO. CK-W.14



FIRE
HYDRANT
ASSEMBLY